

Daily Generation Figures of Power Houses for 03-09-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.990	Unit-I & III are in operation having capacity 300MW and Unit-II having capacity 150 MW is OFF due to High Vibration.
2	Baglihar-II HEP	450.00	107.984	
3	LJHP	105.00	0.00	
4	USHP-II	105.00	15.636	Unit II and III in operation because of less availability of discharge
5	Chenani-I	23.30	2.86149	
6	USHP-I	22.60	2.125	less generation due to under Capital Overhauling of unit II.
7	Ganderbal	15.00	0.1721	Less generation due to damage of C.I Ring of Unit II
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.5529	
10	Chenani-II	2.00	0.19090	
11	Bhaderwah	1.50	0	M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU.
12	Pahalgam	4.50	0	Power House under forced shutdown due to break down of all the three units
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0546	Unit 2nd under complete breakdown. Frequent Load variation for running Unit 1st. Unit 3rd under shutdown due to less availability of load on Plant.
15	Igo Mercellong	3.00	0.07518	
16	Karnah	2.00	0.1900	less gen due to Battery Bank is extremely deteriorated and causes frequent failures.
17	Sanjak	1.26	0.0177	Less availability of load on Plant. Frequent load variation for the running Unit 1st.
18	Haftal	1.00	0.0412	Unit 2nd under shutdown due to less discharge caused by damage of canal.
19	Marpachoo	0.75	0	Power house under shutdown by Civil Division 1st w.e.f. 21/08 onwards for silt clearance.
20	Hunder	0.40	0.02852	Unit II under shutdown due to less discharge of water.
21	Bazgo	0.30	0.00462	Unit II under shutdown due to less discharge of water.
22	Sumoor	0.10	0.01874	Unit II under shutdown due to less discharge of water.
	G.Total	1211.96	201.943	

Total Generation of all powerhouses on 03-09-2015

20.194 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bhaderwah		M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU.
Pahalgam		Power House under forced shutdown due to break down of all the three units
Marpachoo		Marpachoo shutdown from 21.08.2016 due to shutdown taken by Civil Division.
LJHP		Power House under forced shutdown due to break down of all the three units