

Daily Generation Figures of Power Houses for 05-09-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.993	Unit-I & III are in operation having capacity 300MW and Unit-II having capacity 150 MW is OFF due to High Vibration.
2	Baglihar-II HEP	450.00	107.976	
3	LJHP	105.00	0.00	
4	USHP-II	105.00	15.765	Unit II and III in operation because of less availability of discharge
5	Chenani-I	23.30	2.60488	
6	USHP-I	22.60	2.140	less generation due to under Capital Overhauling of unit II.
7	Ganderbal	15.00	0.2978	Less generation due to damage of C.I Ring of Unit II
8	Sewa-III	9.00		
9	Chenani-III	7.50	0.4097	
10	Chenani-II	2.00	0.16790	
11	Bhaderwah	1.50		
12	Pahalgam	4.50	0	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0726	Unit 2nd under complete breakdown. Frequent Load variation for running Unit 1st. Unit 3rd under shutdown due to less availability of load on Plant.
15	Igo Mercellong	3.00	0.06306	
16	Karnah	2.00	0.1810	
17	Sanjak	1.26	0.0175	Less availability of load on Plant. Frequent load variation for the running Unit 1st.
18	Haftal	1.00	0.0413	Unit 2nd under shutdown due to less discharge caused by damage of canal.
19	Marpachoo	0.75	0.0099	Power house under shutdown by Civil Division 1st w.e.f. 21/08 onwards for silt clearance.
20	Hunder	0.40	0.03089	Unit II under shutdown due to less discharge of water.
21	Bazgo	0.30	0.00462	Unit II under shutdown due to less discharge of water.
22	Sumoor	0.10	0.01567	Unit II under shutdown due to less discharge of water.
	G.Total	1211.96	201.791	

Total Generation of all powerhouses on 05-09-2015

20.179 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bhaderwah		M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU.
Pahalgam		Power House under forced shutdown due to break down of all the three units
Marpachoo		Marpachoo shutdown from 21.08.2016 due to shutdown taken by Civil Division.
LJHP		Power House under approved shutdown for 08 days w.e.f. 01-09-2016 (2.00 AM) for carrying out civil related works.