

| Daily Generation Figures of Power Houses for 05-11-2016 |                  |                |                   |  |
|---|------------------|----------------|-------------------|--|
| SNO   | Name of P/H      | Cap.in MW      | Generation in LUs | Remarks  |
| 1   | Baglihar - I HEP | 450.00         | 44.160            |  |
| 2   | Baglihar-II HEP  | 450.00         | 0.000             | Low hydrology  |
| 3   | LJHP             | 105.00         | 4.180             |  |
| 4   | USHP-II          | 105.00         | 4.140             |  |
| 5   | Chenani-I        | 23.30          | 0.50054           |  |
| 6   | USHP-I           | 22.60          | 1.453             |  |
| 7   | Ganderbal        | 15.00          | 0.2400            |  |
| 8   | Sewa-III         | 9.00           | 0                 |  |
| 9   | Chenani-III      | 7.50           | 0.0792            |  |
| 10  | Chenani-II       | 2.00           | 0.01610           |  |
| 11  | Bhaderwah        | 1.50           | 0                 |  |
| 12  | Pahalgam         | 4.50           | 0.009             |  |
| 13  | Stakna           | 4.00           | 0                 |  |
| 14  | Iqbal MHP        | 3.75           | 0.1566            |  |
| 15  | Igo Mercellong   | 3.00           | 0.00000           |  |
| 16  | Karnah           | 2.00           | 0.1820            |  |
| 17  | Sanjak           | 1.26           | 0.0291            |  |
| 18  | Haftal           | 1.00           | 0                 | Power house under shutdown due to non functioning of governor of Unit 1st, Rectification of fused alternator diode. Damage of Sani 11 KV HT cable. |
| 19  | Marpachoo        | 0.75           | 0.015             |  |
| 20  | Hunder           | 0.40           | 0.03084           |  |
| 21  | Bazgo            | 0.30           | 0.00464           |  |
| 22  | Sumoor           | 0.10           | 0.00804           |  |
|   | <b>G.Total</b>   | <b>1211.96</b> | <b>55.204</b>     |  |

Total Generation of all powerhouses on 05-11-2015

5.520 MU's

| Power houses under shut down |            |  |
|------------------------------|------------|--|
| Name of P/H                  | since      | Reason   |
| Sewa-III                     | 23-08-2013 | Breach of canal  |
| Bhaderwah                    |            | M/c-I: Under shutdown due to Governor problem.<br>M/c-II: Under shutdown due to problem in governor.<br>M/c-III: Under shutdown due to problem in OPU. |
| Pahalgam                     |            | Power House under forced shutdown due to break down of all the three units   |
| Iqbal MHP                    |            | Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown.                                    |
| Haftal                       |            | Power house under shutdown due to non functioning of governor of Unit 1st, Rectification of fused alternator diode. Damage of Sani 11 KV HT cable.     |