

Daily Generation Figures of Power Houses for 06-06-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	72.058	UNIT-II OFF Due to High Vibration
2	Baglihar-II HEP	450.00	106.586	
3	LJHP	105.00	14.48	
4	USHP-II	105.00	19.370	
5	Chenani-I	23.30	2.19780	
6	USHP-I	22.60	0.000	
7	Ganderbal	15.00	0.515	
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.4590	
10	Chenani-II	2.00	0.19090	
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0.000	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0936	
15	Igo Mercellong	3.00	0.00720	
16	Karnah	2.00	0.1660	
17	Sanjak	1.26	0.0199	
18	Haftal	1.00	0.0875	
19	Marcpachoo	0.75	0.05375	
20	Hunder	0.40	0.01485	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.00261	
	G.Total	1211.96	216.302	

Total Generation of all powerhouses on 06-06-2015

21.630 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
USHP-I		Power House under shutdown by Civil Division for clearance of debris.
Pahalgam		Damaged Turbine Shaft bearing and Gear Box Problem for Unit II. Boom System was working on Isolation for Unit 3.