

| Daily Generation Figures of Power Houses for 08-09-2016 | | | | |
|---|------------------|----------------|-------------------|---|
| SNO | Name of P/H | Cap.in MW | Generation in LUs | Remarks |
| 1 | Baglihar - I HEP | 450.00 | 70.193 | Unit-I & III are in operation having capacity 300MW and Unit-II having capacity 150 MW is OFF due to High Vibration. |
| 2 | Baglihar-II HEP | 450.00 | 107.991 | |
| 3 | LJHP | 105.00 | 1.940 | Power House put to operation after availing approved shutdown for 08 days w.e.f. 01-09-2016 (2.00 AM) for carrying out civil related works. |
| 4 | USHP-II | 105.00 | 11.125 | Unit II and III in operation because of less availability of discharge |
| 5 | Chenani-I | 23.30 | 1.40817 | M/c-I: Running Hrs.11.40. M/c-II: Running Hrs. 11.45. M/c-III: Running Hrs. 11.50. M/c-IV: Running Hrs. 13.50. (Reduced running hrs for above four machines due to shutdown from 8.00 Hrs. as requested by Mech.Sub.Div. to carry out urgent work & |
| 6 | USHP-I | 22.60 | 2.104 | Unit II under Capital Overhauling. |
| 7 | Ganderbal | 15.00 | 0.1403 | Less generation due to abnormal rise in temperature of Thrust Bearing |
| 8 | Sewa-III | 9.00 | 0 | |
| 9 | Chenani-III | 7.50 | 0.3456 | M/c-I: Running Hrs. 24.00. M/c-II: Under breakdown. M/c-III: Running Hrs. 12.00 due to water shortage. |
| 10 | Chenani-II | 2.00 | 0.09200 | M/c-I: Under shutdown due to water shortage. M/c-II: Running Hrs. 12.00. due to shutdown of CHEP-1 |
| 11 | Bhaderwah | 1.50 | 0 | |
| 12 | Pahalgam | 4.50 | 0 | |
| 13 | Stakna | 4.00 | 0 | |
| 14 | Iqbal MHP | 3.75 | 0 | Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown. |
| 15 | Igo Mercellong | 3.00 | 0.07400 | |
| 16 | Karnah | 2.00 | 0.1770 | |
| 17 | Sanjak | 1.26 | 0.0195 | Less availability of load on Plant.Frequent load variation for the running Unit 1st. |
| 18 | Haftal | 1.00 | 0.0420 | Unit 2nd under shutdown due to less discharge caused by damage of canal. |
| 19 | Marpachoo | 0.75 | 0.0325 | Power house under shutdown by Civil Division 1st w.e.f. 21/08 onwards for silt clearance. |
| 20 | Hunder | 0.40 | 0.02952 | Unit II under shutdown due to less discharge of water. |
| 21 | Bazgo | 0.30 | 0.00467 | Unit II under shutdown due to less discharge of water. |
| 22 | Sumoor | 0.10 | 0.01892 | Unit II under shutdown due to less discharge of water. |
| | G.Total | 1211.96 | 195.736 | |

Total Generation of all powerhouses on 08-09-2015

19.574 MU's

| Power houses under shut down | | |
|------------------------------|------------|--|
| Name of P/H | since | Reason |
| Sewa-III | 23-08-2013 | Breach of canal |
| Bhaderwah | | M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU. |
| Pahalgam | | Power House under forced shutdown due to break down of all the three units |
| Iqbal MHP | | Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown. |