

Daily Generation Figures of Power Houses for 09-05-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.995	Unit II under shutdown for checkup by Experts due to repeatedly Vibrations
2	Baglihar-II HEP	450.00	108.002	
3	LJHP	105.00	22.02	
4	USHP-II	105.00	10.330	Emergency shutdown of Unit I at 14.50 due to abnormal sound of the machine. Inspection is underway. Unit 2 = Excitation System failure at 14.45. Unit started after replacement of shaft sleeve.
5	Chenani-I	23.30	2.30313	
6	USHP-I	22.60	0	Under Shutdown due to leakage in canal.
7	Ganderbal	15.00	0.720	
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.5508	
10	Chenani-II	2.00	0.19550	
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0.211	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0738	
15	Igo Mercellong	3.00	0.02880	
16	Karnah	2.00	0.1970	
17	Sanjak	1.26	0.0167	
18	Haftal	1.00	0	
19	Marcpachoo	0.75	0.02500	
20	Hunder	0.40	0.01536	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.00189	
	G.Total	1211.96	216.686	

Total Generation of all powerhouses on 09-05-2015 = **21.669 MU's**

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Haftal		Power house under winter shutdown.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
USHP-I		Under Shutdown due to leakage in canal.