

Daily Generation Figures of Power Houses for 09-09-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.970	Unit-I & III are in operation having capacity 300MW and Unit-II having capacity 150 MW is OFF due to High Vibration.
2	Baglihar-II HEP	450.00	107.990	
3	LJHP	105.00	20.643	
4	USHP-II	105.00	9.645	Unit II and III in operation because of less availability of discharge
5	Chenani-I	23.30	2.19304	M/c-I: Running Hrs. 24.00. M/c-II: Running Hrs. 24.00. M/c-III: Running Hrs. 24.00. M/c-IV: Running Hrs. 24.00. M/c-V: Under shutdown due to water shortage.
6	USHP-I	22.60	2.118	Unit II under Capital Overhauling.
7	Ganderbal	15.00	0.2393	Less generation due to abnormal rise in temperature of Thrust Bearing
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.4421	M/c-I: Running Hrs. 23.35 due to 33 KV line tripped. M/c-II: Under breakdown. M/c-III: Running Hrs. 19.55 due to 33 KV line tripped and water shortage.
10	Chenani-II	2.00	0.17710	M/c-I: Under shutdown due to water shortage. M/c-II: Running Hrs. 24.00.
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0	
13	Stakna	4.00		
14	Iqbal MHP	3.75	0	Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown.
15	Igo Mercellong	3.00	0.06960	Less availability of load on Plant.Frequent load variation for the running Unit 1st.
16	Karnah	2.00	0.1710	Unit 2nd under shutdown due to less discharge caused by damage of canal.
17	Sanjak	1.26	0.0179	Power house under shutdown by Civil Division 1st w.e.f. 21/08 onwards for silt clearance.
18	Haftal	1.00	0.0423	Unit II under shutdown due to less discharge of water.
19	Marpachoo	0.75	0.0325	Unit II under shutdown due to less discharge of water.
20	Hunder	0.40	0.02880	Unit II under shutdown due to less discharge of water.
21	Bazgo	0.30	0.00465	
22	Sumoor	0.10	0.01613	
	G.Total	1211.96	215.800	

Total Generation of all powerhouses on 08-09-2015

21.580 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bhaderwah		M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU.
Pahalgam		Power House under forced shutdown due to break down of all the three units
Iqbal MHP		Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown.