

Daily Generation Figures of Power Houses for 10-09-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.980	
2	Baglihar-II HEP	450.00	107.990	
3	LJHP	105.00	21.430	
4	USHP-II	105.00	10.730	
5	Chenani-I	23.30	2.27066	
6	USHP-I	22.60	1.843	
7	Ganderbal	15.00	0.1998	
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.3348	
10	Chenani-II	2.00	0.18860	
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0	
13	Stakna	4.00		
14	Iqbal MHP	3.75	0	Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown.
15	Igo Mercellong	3.00	0	Problem in AVR.
16	Karnah	2.00	0.1300	
17	Sanjak	1.26	0.0166	Less availability of load on Plant.Frequent load variation for the running Unit 1st.
18	Haftal	1.00	0.0415	Unit 2nd under shutdown due to less discharge caused by damage of canal.
19	Marpachoo	0.75	0.0313	Power house under shutdown by Civil Division 1st w.e.f. 21/08 onwards for silt clearance.
20	Hunder	0.40	0.03120	Unit II under shutdown due to less discharge of water.
21	Bazgo	0.30	0.00442	Unit II under shutdown due to less discharge of water.
22	Sumoor	0.10	0.01613	Unit II under shutdown due to less discharge of water.
	G.Total	1211.96	217.238	

Total Generation of all powerhouses on 10-09-2015

21.724 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bhaderwah		M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU.
Pahalgam		Power House under forced shutdown due to break down of all the three units
Iqbal MHP		Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown.