

| Daily Generation Figures of Power Houses for 15-05-2016 | | | | |
|---|------------------|----------------|-------------------|--|
| SNO | Name of P/H | Cap.in MW | Generation in LUs | Remarks |
| 1 | Baglihar - I HEP | 450.00 | 107.975 | Unit II under shutdown for checkup by Experts due to repeatedly Vibrations |
| 2 | Baglihar-II HEP | 450.00 | 107.999 | |
| 3 | LJHP | 105.00 | 14.79 | |
| 4 | USHP-II | 105.00 | 11.330 | |
| 5 | Chenani-I | 23.30 | 2.29759 | |
| 6 | USHP-I | 22.60 | 1.174 | |
| 7 | Ganderbal | 15.00 | 0.720 | |
| 8 | Sewa-III | 9.00 | 0 | |
| 9 | Chenani-III | 7.50 | 0.6044 | |
| 10 | Chenani-II | 2.00 | 0.18860 | |
| 11 | Bhaderwah | 1.50 | 0 | |
| 12 | Pahalgam | 4.50 | 0.200 | |
| 13 | Stakna | 4.00 | 0 | |
| 14 | Iqbal MHP | 3.75 | 0.0810 | |
| 15 | Igo Mercellong | 3.00 | 0.02880 | |
| 16 | Karnah | 2.00 | 0.1940 | |
| 17 | Sanjak | 1.26 | 0.0179 | |
| 18 | Haftal | 1.00 | 0 | |
| 19 | Marpachoo | 0.75 | 0 | |
| 20 | Hunder | 0.40 | 0.01485 | |
| 21 | Bazgo | 0.30 | 0 | |
| 22 | Sumoor | 0.10 | 0.00162 | |
| | G.Total | 1211.96 | 247.617 | |

Total Generation of all powerhouses on 15-05-2015 =

24.762 MU's

| Power houses under shut down | | |
|------------------------------|------------|---|
| Name of P/H | since | Reason |
| Sewa-III | 23-08-2013 | Breach of canal |
| Haftal | | Power house under winter shutdown. |
| Bazgo | | Bazgo under shutdown due to diversion of water for irrigation by the villagers. |
| Bhaderwah | | M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU. |
| Marpachoo | | Marpachoo shutdown due to damage of Thrust Pad. |