

| Daily Generation Figures of Power Houses for 15-10-2016 | | | | |
|---|------------------|----------------|-------------------|---------------|
| SNO | Name of P/H | Cap.in MW | Generation in LUs | Remarks |
| 1 | Baglihar - I HEP | 450.00 | 72.015 | |
| 2 | Baglihar-II HEP | 450.00 | 8.576 | Low hydrology |
| 3 | LJHP | 105.00 | 6.080 | |
| 4 | USHP-II | 105.00 | 4.850 | |
| 5 | Chenani-I | 23.30 | 0.80625 | |
| 6 | USHP-I | 22.60 | 2.019 | |
| 7 | Ganderbal | 15.00 | 0.2400 | |
| 8 | Sewa-III | 9.00 | | |
| 9 | Chenani-III | 7.50 | 0.1760 | |
| 10 | Chenani-II | 2.00 | 0.05060 | |
| 11 | Bhaderwah | 1.50 | | |
| 12 | Pahalgam | 4.50 | | |
| 13 | Stakna | 4.00 | | |
| 14 | Iqbal MHP | 3.75 | | |
| 15 | Igo Mercellong | 3.00 | 0.12480 | |
| 16 | Karnah | 2.00 | 0.1630 | |
| 17 | Sanjak | 1.26 | 0.0203 | |
| 18 | Haftal | 1.00 | 0.0525 | |
| 19 | Marcpachoo | 0.75 | 0.0125 | |
| 20 | Hunder | 0.40 | 0.03084 | |
| 21 | Bazgo | 0.30 | 0.00450 | |
| 22 | Sumoor | 0.10 | 0.00924 | |
| | G.Total | 1211.96 | 95.231 | |

Total Generation of all powerhouses on 15-10-2015

9.523 MU's

| Power houses under shut down | | |
|------------------------------|------------|--|
| Name of P/H | since | Reason |
| Sewa-III | 23-08-2013 | Breach of canal |
| Bhaderwah | | M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU. |
| Pahalgam | | Power House under forced shutdown due to break down of all the three units |
| Iqbal MHP | | Shutdown of power house due to damage of upstream shaft seal bearing of Unit-I & Unit 2nd under complete breakdown. |