

Daily Generation Figures of Power Houses for 19-05-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	107.995	
2	Baglihar-II HEP	450.00	107.991	
3	LJHP	105.00	13.88	Less energy due to Unit 3 under forced shutdown.
4	USHP-II	105.00	14.180	Unit 1 stopped due to PRV Rod failure.
5	Chenani-I	23.30	1.91980	M/c-I: Running Hrs. 11.55 due to problem in nozzle jet assembly. M/c-II under shutdown due to problem in governor. M/c-III under shutdown due to damage of NLC Panel, CT's, PT's. M/c-IV: Running Hrs. 24.00. M/c-V: Running Hrs. 24.00.
6	USHP-I	22.60	2.160	
7	Ganderbal	15.00	0.685	33 KV Habak Ganderbal line tripping and routine maintenance.
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.6052	M/c-I: Running Hrs. 24.00. M/c-II under breakdown. M/c-III: Running Hrs. 24.00.
10	Chenani-II	2.00	0.12650	M/c-I under shutdown due to shortage of water from CHEP-I. M/c-II: Running Hrs. 24.00.
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0.366	Gear Box Problem for Unit II. Low Grid Voltage. Abnormal Gear Box temperature for Unit I. Pressure problem in Gear Box for Unit I. Oil Seal problem of Turbine Shaft of Unit
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0882	
15	Igo Mercellong	3.00	0.01920	
16	Karnah	2.00	0.1660	
17	Sanjak	1.26	0.0153	
18	Haftal	1.00	0	
19	Marpachoo	0.75	0	
20	Hunder	0.40	0.01536	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.00189	
	G.Total	1211.96	250.214	

Total Generation of all powerhouses on 19-05-2015 = **25.021 MU's**

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Haftal		Power house under winter shutdown.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
Marpachoo		Marpachoo shutdown due to damage of Thrust Pad.