

Daily Generation Figures of Power Houses for 20-03-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar HEP	450.00	87.835	Due to Low Hydrology
2	LJHP	105.00	18.71	
3	USHP-II	105.00	4.400	Unit 1 EOC Motor Failure. Unit 2 stopped as the discharge in Wangath Link Canal restricted on instructions of Civil Executive Engineer. Unit 3 stopped due to low discharge.
4	Chenani-I	23.30	0.95594	
5	USHP-I	22.60	0.656	
6	Ganderbal	15.00	0	
7	Sewa-III	9.00	0	
8	Chenani-III	7.50	0.19296	
9	Chenani-II	2.00	0.08280	
10	Bhaderwah	1.50	0.0441	
11	Pahalgam	4.50	0.163	
12	Stakna	4.00	0	
13	Iqbal MHP	3.75	0.0486	
14	Igo Mercellong	3.00	0	
15	Karnah	2.00	0.2130	
16	Sanjak	1.26	0	
17	Haftal	1.00	0	
18	Marpachoo	0.75	0	
19	Hunder	0.40	0.02232	
20	Bazgo	0.30	0	
21	Sumoor	0.10	0.00252	
	G.Total	761.96	113.326	

Total Generation of all powerhouses on 20-03-2015 = **11.333 MU's**

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Marpachoo		Marpochoo winter shutdown.
Igo Marchellong		Power house under winter shutdown.
Haftal		Power house under winter shutdown.
Sanjak		Power house under winter shutdown.
Ganderbal		Power House under forced shutdown due to damaged Auxiliary AVR and Bearings of Unit 4. Repair work under progress.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.