Daily Generation Figures of Power Houses for 20-05-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	107.990	
2	Baglihar-II HEP	450.00	107.990	
3	LJHP	105.00	14.21	
4	USHP-II	105.00	15.480	
5	Chenani-I	23.30	2.49717	M/c-I: Running Hrs. 24.00. M/c-II: Running Hrs. 13.30 Hrs. (M/c put on load at 10:30 Hrs). M/c-III under shutdown due to damage of NLC Panel, CT's, PT's. M/c-IV: Running Hrs. 24.00. M/c-V: Running Hrs. 24.00.
6	USHP-I	22.60	2.040	
7	Ganderbal	15.00	0.698	
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.6127	M/c-I: Running Hrs. 23.35 due to 33 KV line tripped. M/c-II under breakdown. M/c-III: Running Hrs. 23.25 due to 33 KV line tripped.
10	Chenani-II	2.00	0.19320	M/c-I under repair. M/c-II: Running Hrs. 24.00.
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0.220	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0900	
15	Igo Mercellong	3.00	0.02880	
16	Karnah	2.00	0.1880	
17	Sanjak	1.26	0.0161	
18	Haftal	1.00	0	
19	Marcpachoo	0.75	0.03375	
20	Hunder	0.40	0.01536	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.00189	
	G.Total	**1211.96**	**252.305**	

Total Generation of all powerhouses on 20-05-2015 = 25.230 MU's

Power houses under shut down		
Name of P/H	since	Reasion
Sewa-III	23-08-2013	Breach of canal
Haftal		Power house under winter shutdown.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.