

Daily Generation Figures of Power Houses for 21-03-2016

| SNO | Name of P/H | Cap.in MW | Generation in LUs | Remarks |
|-----|----------------|---------------|-------------------|--|
| 1 | Baglihar HEP | 450.00 | 62.606 | Due to Low Hydrology |
| 2 | LJHP | 105.00 | 20.00 | |
| 3 | USHP-II | 105.00 | 3.600 | Unit 1 EOC Motor Failure. Unit 2 stopped as the discharge in Wangath Link Canal restricted on instructions of Civil Executive Engineer. Unit 3 stopped due to low discharge. |
| 4 | Chenani-I | 23.30 | 1.44698 | |
| 5 | USHP-I | 22.60 | 0.550 | |
| 6 | Ganderbal | 15.00 | 0 | |
| 7 | Sewa-III | 9.00 | 0 | |
| 8 | Chenani-III | 7.50 | 0.22068 | |
| 9 | Chenani-II | 2.00 | 0.12560 | |
| 10 | Bhaderwah | 1.50 | 0.0570 | |
| 11 | Pahalgam | 4.50 | 0.176 | |
| 12 | Stakna | 4.00 | 0 | |
| 13 | Iqbal MHP | 3.75 | 0.0828 | |
| 14 | Igo Mercellong | 3.00 | 0 | |
| 15 | Karnah | 2.00 | 0.2100 | |
| 16 | Sanjak | 1.26 | 0 | |
| 17 | Haftal | 1.00 | 0 | |
| 18 | Marcpachoo | 0.75 | 0 | |
| 19 | Hunder | 0.40 | 0.02079 | |
| 20 | Bazgo | 0.30 | 0 | |
| 21 | Sumoor | 0.10 | 0.00140 | |
| | G.Total | 761.96 | 89.097 | |

Total Generation of all powerhouses on 21-03-2015 = **8.910 MU's**

Power houses under shut down

| Name of P/H | since | Reason |
|-----------------|------------|--|
| Sewa-III | 23-08-2013 | Breach of canal |
| Marcpachoo | | Marpochoo winter shutdown. |
| Igo Marchellong | | Power house under winter shutdown. |
| Haftal | | Power house under winter shutdown. |
| Sanjak | | Power house under winter shutdown. |
| Ganderbal | | Power House under forced shutdown due to damaged Auxiliary AVR and Bearings of Unit 4. Repair work under progress. |
| Bazgo | | Bazgo under shutdown due to diversion of water for irrigation by the villagers. |