| Daily Generation Figures of Power Houses for 22-03-2016 | | | | |
|---|---|---|---|---|
| SNO | Name of P/H | Cap.in MW | Generation in LUs | Remarks |
| 1 | Baglihar HEP | 450.00 | 47.207 | Due to Low Hydrology |
| 2 | LJHP | 105.00 | 20.42 | |
| 3 | USHP-II | 105.00 | 6.110 | Unit 1 EOC Motor Failure. Unit 2 stopped as the discharge in Wangath LInk Canal restricted on instructions of Civil Executive Engineer. Unit 3 stopped due to low discharge. |
| 4 | Chenani-I | 23.30 | 1.48896 | |
| 5 | USHP-I | 22.60 | 1.910 | |
| 6 | Ganderbal | 15.00 | 0.1425 | |
| 7 | Sewa-III | 9.00 | 0 | |
| 8 | Chenani-III | 7.50 | 0 | |
| 9 | Chenani-II | 2.00 | 0.13340 | |
| 10 | Bhaderwah | 1.50 | 0.0435 | |
| 11 | Pahalgam | 4.50 | 0.180 | |
| 12 | Stakna | 4.00 | 0 | |
| 13 | Iqbal MHP | 3.75 | 0.1206 | |
| 14 | Igo Mercellong | 3.00 | 0 | |
| 15 | Karnah | 2.00 | 0.1910 | |
| 16 | Sanjak | 1.26 | 0 | |
| 17 | Haftal | 1.00 | 0 | |
| 18 | Marcpachoo | 0.75 | 0 | |
| 19 | Hunder | 0.40 | 0.02232 | |
| 20 | Bazgo | 0.30 | 0 | |
| 21 | Sumoor | 0.10 | 0.00162 | |
| | **G.Total** | **761.96** | **77.971** | |

**Total Generation of all powerhouses on 22-03-2015 =** **7.797 MU's**

| Power houses under shut down | | |
|---|---|---|
| Name of P/H | since | Reasion |
| Sewa-III | 23-08-2013 | Breach of canal |
| Marcpachoo | | Marpochoo winter shutdown. |
| Igo Marchellong | | Power house under winter shutdown. |
| Haftal | | Power house under winter shutdown. |
| Sanjak | | Power house under winter shutdown. |
| Bazgo | | Bazgo under shutdown due to diversion of water for irrigation by the villagers. |

| | | |
|---|---|---|
| Chenani-III | | M/c-I under shutdown due to problem in air compressor. M/c-II under breakdown. M/c-IIIunder shutdown due to problem in air compressor. |