

Daily Generation Figures of Power Houses for 22-05-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	100.755	
2	Baglihar-II HEP	450.00	84.882	
3	LJHP	105.00	14.47	Unit 3 under forced shutdown. Routine trash cleaning at forebay and barrage undertaken.
4	USHP-II	105.00	17.840	Unit 1 started after replacement of PRV Rod.
5	Chenani-I	23.30	2.72844	M/c-III under shutdown due to damage of NLC Panel, CT's, PT's.
6	USHP-I	22.60	2.010	Unit II under Capital Overhauling.
7	Ganderbal	15.00	0.720	
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.5126	M/c-II under breakdown.
10	Chenani-II	2.00	0.19780	M/c-I under repair.
11	Bhaderwah	1.50	0	M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
12	Pahalgam	4.50	0.156	Damaged Turbine Shaft bearing and Gear Box Problem for Unit II. Low Grid Voltage. Abnormal Gear Box temperature for Unit I. Pressure problem in Gear Box for Unit I. Oil Seal problem of Turbine Shaft of Unit I. DC supply failure for Unit 1st.
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0864	
15	Igo Mercellong	3.00	0.01440	
16	Karnah	2.00	0.1820	
17	Sanjak	1.26	0.0139	
18	Haftal	1.00	0	Haftal power house under winter shutdown.
19	Marpachoo	0.75	0.03875	
20	Hunder	0.40	0.01485	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.00189	
	G.Total	1211.96	224.624	

Total Generation of all powerhouses on 22-05-2015

22.462 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Haftal		Power house under winter shutdown.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.