

Daily Generation Figures of Power Houses for 23-06-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.980	UNIT-II OFF Due to High Vibration
2	Baglihar-II HEP	450.00	71.988	Unit 4 Tripped at 11:01 Pm due to excitation system failure on 22-06-2016. Outage code 5085
3	LJHP	105.00	13.16	
4	USHP-II	105.00	23.500	
5	Chenani-I	23.30	2.77200	
6	USHP-I	22.60	2.240	
7	Ganderbal	15.00	0.250	
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.5566	
10	Chenani-II	2.00	0.19320	
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0864	
15	Igo Mercellong	3.00	0.02880	
16	Karnah	2.00	0.0780	
17	Sanjak	1.26	0.0153	
18	Haftal	1.00	0.0430	
19	Marcpachoo	0.75	0.03625	
20	Hunder	0.40	0.02640	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.01416	
	G.Total	1211.96	186.968	

Total Generation of all powerhouses on 23-06-2015

18.697 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
Pahalgam		Under shutdown due to abnormal production of unusual noise and high temperature in channel 6 of gear box .