

Daily Generation Figures of Power Houses for 24-05-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	102.450	
2	Baglihar-II HEP	450.00	96.418	
3	LJHP	105.00	14.67	
4	USHP-II	105.00	16.870	
5	Chenani-I	23.30	2.67141	M/c-I: Running Hrs. 21.30 (Due to 132 KV line tripped from Grid Station Udhampur) . M/c-II: Running Hrs. 21.27 (Due to 132 KV line tripped from Grid Station Udhampur). M/c-III under shutdown due to damage of NLC Panel, CT's, PT's. M/c-IV: Running Hrs. 21.20 (Due to 132 KV line tripped from Grid Station Udhampur). M/c-V: Running Hrs. 21.25 (Due to 132 KV line tripped from Grid Station Udhampur).
6	USHP-I	22.60	1.180	
7	Ganderbal	15.00	0.361	
8	Sewa-III	9.00		
9	Chenani-III	7.50	0.3931	M/c-I: Running Hrs. 20.55 (Due to 33 kv line tripped). M/c-II under breakdown. M/c-III: Running Hrs. 12.00 (Due to 33 kv line tripped & OPU Panel fault).
10	Chenani-II	2.00	0.15870	M/c-I under repair. M/c-II: Running Hrs. 20.25 (Due to 6.6 KV line tripped from CHEP-I).
11	Bhaderwah	1.50	0	M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
12	Pahalgam	4.50	0.064	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0828	
15	Igo Mercellong	3.00	0.01680	
16	Karnah	2.00	0.1420	
17	Sanjak	1.26	0.0177	
18	Haftal	1.00	0	
19	Marpachoo	0.75	0.03375	
20	Hunder	0.40	0.01536	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.00162	
	G.Total	1211.96	235.546	

Total Generation of all powerhouses on 24-05-2015

23.555 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Haftal		Power house under winter shutdown.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.