

Daily Generation Figures of Power Houses for 26-05-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	95.895	
2	Baglihar-II HEP	450.00	106.754	
3	LJHP	105.00	14.60	
4	USHP-II	105.00	22.050	
5	Chenani-I	23.30	2.66082	M/c-I: Running Hrs. 24.00. M/c-II: Running Hrs. 24.00. M/c-III under shutdown due to damage of NLC Panel, CT's, PT's. M/c-IV: Running Hrs. 24.00. M/c-V: Running Hrs. 24.00.
6	USHP-I	22.60		
7	Ganderbal	15.00	0.622	
8	Sewa-III	9.00		
9	Chenani-III	7.50	0.5072	M/c-I: Running Hrs. 24.00. M/c-II under breakdown. M/c-III: Running Hrs. 24.00.
10	Chenani-II	2.00	0.18400	M/c-I under repair. M/c-II: Running Hrs. 24.00.
11	Bhaderwah	1.50		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
12	Pahalgam	4.50	0.131	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0918	
15	Igo Mercellong	3.00	0.02880	
16	Karnah	2.00	0.1790	
17	Sanjak	1.26	0.0174	
18	Haftal	1.00	0.0768	
19	Marcpachoo	0.75	0.03500	
20	Hunder	0.40	0.01485	
21	Bazgo	0.30	0	
22	Sumoor	0.10	0.00243	
	<b>G.Total</b>	<b>1211.96</b>	<b>243.850</b>	

Total Generation of all powerhouses on 26-05-2015

24.385 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Bhaderwah		M/c-I is under shutdown due to Governor problem. M/c-II: is under shutdown due to problem in governor. M/c-III is under shutdown due to problem in OPU.
USHP-I		Power House under forced shutdown from Civil Side due to sliding of rock in Canal near Gund.