

Daily Generation Figures of Power Houses for 28-03-2016

SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar HEP	450.00	84.520	Due to Low Hydrology
2	LJHP	105.00	19.05	
3	USHP-II	105.00	11.530	Unit 1 EOC Motor Failure. Unit 2 stopped as the discharge in Wangath Link Canal restricted on instructions of Civil Executive Engineer. Unit 3 stopped due to low discharge
4	Chenani-I	23.30	2.44965	
5	USHP-I	22.60	2.132	
6	Ganderbal	15.00	0	
7	Sewa-III	9.00	0	
8	Chenani-III	7.50	0	
9	Chenani-II	2.00	0.19780	
10	Bhaderwah	1.50	0.0573	
11	Pahalgam	4.50	0.181	
12	Stakna	4.00	0	
13	Iqbal MHP	3.75	0.1674	
14	Igo Mercellong	3.00	0	
15	Karnah	2.00	0.1910	
16	Sanjak	1.26	0	
17	Haftal	1.00	0	
18	Marcpachoo	0.75	0	
19	Hunder	0.40	0.01536	
20	Bazgo	0.30	0	
21	Sumoor	0.10	0.00162	
	G.Total	761.96	120.493	

Total Generation of all powerhouses on 28-03-2015 = **12.049 MU's**

Power houses under shut down

Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Marpachoo		Marpachoo winter shutdown.
Igo Marchellong		Power house under winter shutdown.
Haftal		Power house under winter shutdown.
Sanjak		Power house under winter shutdown.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.

Chenani-III		M/c-I under shutdown due to problem in air compressor. M/c-II under breakdown. M/c-III under shutdown due to problem in air compressor.
Ganderbal		Generation Nil due to Excess water leakage in Bypass Valve of Unit I .