

**Daily Generation Figures of Power Houses for 30-08-2016**

SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.938	
2	Baglihar-II HEP	450.00	106.091	
3	LJHP	105.00	14.55	
4	USHP-II	105.00	15.450	
5	Chenani-I	23.30	2.85120	
6	USHP-I	22.60	2.090	
7	Ganderbal	15.00	0.1050	Less generation due to damage of C.I Ring of Unit II
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.3254	
10	Chenani-II	2.00	0.19090	
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0	
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0852	Unit IInd under complete breakdown. Frequent load variation for running Unit 1st. Unit 3rd under shutdown due to less availability of load on plant.
15	Igo Mercellong	3.00	0.06786	Unit-II under shutdown due to damage of Gear box.
16	Karnah	2.00	0.1190	
17	Sanjak	1.26	0.0175	Less availibility of load on plant. Frequent load variation for the running of Unit 1st.
18	Haftal	1.00	0.0416	Unit 2nd under shutdown due to less discharge caused by damage of canal.
19	Marpachoo	0.75	0	Power house under shutdown by Civil Division 1st w.e.f. 21/08 onwards for silt clearance.
20	Hunder	0.40	0.03089	Unit II under shutdown due to less discharge of water.
21	Bazgo	0.30	0.0046	Unit II under shutdown due to less discharge of water.
22	Sumoor	0.10	0.01597	Unit II under shutdown due to less discharge of water.
	<b>G.Total</b>	<b>1211.96</b>	<b>213.974</b>	

**Total Generation of all powerhouses on 30-08-2015      21.397 MU's**

**Power houses under shut down**

Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bhaderwah		M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU.
Pahalgam		Under shutdown due to abnormal production of unusual noise and high temperature in channel 6 of gear box Unit III. Unit I & II under shutdown due to breakdown.
Marpachoo		Marpachoo shutdown from 21.08.2016 due to shutdown taken by Civil Divison.