

**Daily Generation Figures of Power Houses for 31-03-2016**

SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar HEP	450.00	108.013	Due to Low Hydrology
2	LJHP	105.00	22.63	
3	USHP-II	105.00	12.000	Unit 1 EOC Motor Failure. Unit 2 stopped as the discharge in Wangath Link Canal restricted on instructions of Civil Executive Engineer. Unit 3 stopped due to low discharge
4	Chenani-I	23.30	2.49480	
5	USHP-I	22.60	2.127	
6	Ganderbal	15.00	0.600	
7	Sewa-III	9.00	0	
8	Chenani-III	7.50	0	
9	Chenani-II	2.00	0.18630	
10	Bhaderwah	1.50	0.0570	
11	Pahalgam	4.50	0.250	
12	Stakna	4.00	0	
13	Iqbal MHP	3.75	0.1818	
14	Igo Mercellong	3.00	0	
15	Karnah	2.00	0.2190	
16	Sanjak	1.26	0.0309	
17	Haftal	1.00	0	
18	Marcpachoo	0.75	0	
19	Hunder	0.40	0.01440	
20	Bazgo	0.30	0	
21	Sumoor	0.10	0.00162	
	<b>G.Total</b>	<b>761.96</b>	<b>148.805</b>	

Total Generation of all powerhouses on 31-03-2015 = **14.881 MU's**

**Power houses under shut down**

Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Marcpachoo		Marpochoo winter shutdown.
Igo Marchellong		Power house under winter shutdown.
Haftal		Power house under winter shutdown.
Bazgo		Bazgo under shutdown due to diversion of water for irrigation by the villagers.
Chenani-III		M/c-I under shutdown due to problem in air compressor. M/c-II under breakdown. M/c-III under shutdown due to problem in air compressor.