

Daily Generation Figures of Power Houses for 31-08-2016				
SNO	Name of P/H	Cap.in MW	Generation in LUs	Remarks
1	Baglihar - I HEP	450.00	71.720	Unit-I & III are in operation having capacity 300MW and Unit-II having capacity 150 MW is OFF due to High Vibration.
2	Baglihar-II HEP	450.00	107.988	
3	LJHP	105.00	12.75	Power House under approved shutdown for 08 days w.e.f. 01-09-2016 (2.00 AM)
4	USHP-II	105.00	14.930	
5	Chenani-I	23.30	2.85516	
6	USHP-I	22.60	2.010	Unit II under Capital Overhauling.
7	Ganderbal	15.00	0.2800	
8	Sewa-III	9.00	0	
9	Chenani-III	7.50	0.5497	
10	Chenani-II	2.00	0.18860	
11	Bhaderwah	1.50	0	
12	Pahalgam	4.50	0	Under shutdown due to abnormal production of unusual noise and high temperature in channel 6 of gear box Unit III. Unit I & II under shutdown due to breakdown.
13	Stakna	4.00	0	
14	Iqbal MHP	3.75	0.0814	Unit II under complete breakdown. Frequent load variation for running Unit 1st. Unit 3rd under shutdown due to less availability of load on plant.
15	Igo Mercellong	3.00	0.06786	Unit-II under shutdown due to damage of Gear box.
16	Karnah	2.00	0.1940	
17	Sanjak	1.26	0.0178	Less availability of load on plant. Frequent load variation for the running of Unit 1st.
18	Haftal	1.00	0.0408	Unit 2nd under shutdown due to less discharge caused by damage of canal.
19	Marpachoo	0.75	0	Power house under shutdown by Civil Division 1st w.e.f. 21/08 onwards for silt clearance.
20	Hunder	0.40	0.03089	Unit II under shutdown due to less discharge of water.
21	Bazgo	0.30	0.0046	Unit II under shutdown due to less discharge of water.
22	Sumoor	0.10	0.01597	Unit II under shutdown due to less discharge of water.
	G.Total	1211.96	213.725	

Total Generation of all powerhouses on 31-08-2015

21.372 MU's

Power houses under shut down		
Name of P/H	since	Reason
Sewa-III	23-08-2013	Breach of canal
Bhaderwah		M/c-I: Under shutdown due to Governor problem. M/c-II: Under shutdown due to problem in governor. M/c-III: Under shutdown due to problem in OPU.
Pahalgam		Under shutdown due to abnormal production of unusual noise and high temperature in channel 6 of gear box Unit III. Unit I & II under shutdown due to breakdown.
Marpachoo		Marpachoo shutdown from 21.08.2016 due to shutdown taken by Civil Division.